Facility Registration # 25.0960

Test and Inspection Report in Accordance with CSA B620

Dandy Oil Products Ltd.

15 Challenger Crescent Sherwood Park, AB T8H 2J6

780-452-1104

Tank Owner - if different from above

Tank Owner

DANDY OIL PRODUCTS

Address

15630 118 AVE NW EDMONTON, T5V 1C4

Phone #

780-818-0757

Tank Data	
Serial Number	14314
Unit Number	401
TC Spec.	TC 406
Date of Manufacture	APRIL 2006
Certification Date	05-10
VIN	2C9LEA2S861026064
Tank Manufacturer	COLUMBIA REMTEC
Assembler	COLUMBIA REMTEC
MDIN	23304172
MAWN	21 KPA
Test P.	34.5 KPA
Min. Thick Head	4.39 MM
Min. Shell Thick	5.75 MM
Exposed Surface	9.0/12.9/14.8
Cap.	23000 LITRES
Original Test Date	MARCH 2017
Compartment Capacity – 1	14000 LITRES
Compartment Capacity - 2	5000 LITRES
Compartment Capacity - 3	14000 LITRES
Compartment Capacity - 4	N/A
Compartment Capacity - 5	N/A

Test and Inspection Report in Accordance with CSA B620

Dandy Oil Products Ltd.

15 Challenger Crescent Sherwood Park, AB T8H 2J6 \$\approx 780-452-1104 Facility Registration # 25.0960

External Visual Inspection	" V "				
Inspection Date	MAY 28TH 2019				
Inspection Date Expiry	SUNDAY MAY 31ST 2020				
PRV set to Discharge P	1.5 PSI				
Manway Pressure	3.5 PSI				
Inspection	Inspect jacketing for dents, digs, scrapes gouges, perforations, stains, or other defects or signs of damage to the inner-vessel or any other condition that might make it unsafe as per 7.2.1(a) Complies Reject Retest Complies				
	Inspect the entire area of head and shell for dents, gouges, bulges, corrosion, abrasion, cracks, or signs of leakage or other conditions that might render it unsafe for transport per 7.2.1(a) ☑ Complies ☐ Reject ☐ Retest Complies				
	Inspect the entire length of every weld for cracks, defects or signs of leakage as per 7.2.1(a) ☑ Complies ☐ Reject ☐ Retest Complies				
	Ensure devices for tightening manhole covers are operative and covers are leak tight as per 7.2.1(b) ☑ Complies ☐ Reject ☐ Retest Complies				
	Check all valves, vents, emergency devices and remote closures for corrosion, distortion, cracks, signs of weakness and loose or missing fasteners as per 7.2.1(c) ☑ Complies □ Reject □ Retest Complies				
	Ensure all required markings are legible including manway, PRV, couplings, valves and specification plates as per 7.2.1(e) ☑ Complies ☐ Reject ☐ Retest Complies				
	Inspect supporting structures, pads, bolsters, tie-downs and protective devices for dents, distortion, cracks signs of weakness and loose or missing fasteners as per 7.2.1(f) ☑ Complies □ Reject □ Retest Complies				
	Ensure accompanying or mounted hoses comply with inspection and marking requirements as per 7.2.10.4 and 7.2.10.6 ☐ Complies ☑ Reject ☑ Retest Complies				
	Check to ensure voids are unplugged and show no signs of leakage as per 7.2.1.2 ☑ Complies ☐ Reject ☐ Retest Complies				
	Corroded or abraded areas are thickness tested as per 7.2.1.2 ☑ Complies □ Reject □ Retest Complies				
	All pressure relief devices are inspected for corrosion or damage as per 7.2.1.4 ☐ Complies ☑ Reject ☑ Retest Complies				
	If lading is corrosive to PRV: re-closing pressure relief valves are replaced or tested as per 7.2.1.4 ☑ Complies ☐ Reject ☐ Retest Complies				
	Gaskets on full opening rear head is inspected and replaced if cut, cracked or split as per 7.2.1.5 ☐ Complies ☐ Reject ☐ Retest Complies				
	Internal self-closing valve and off truck emergency shutdown system is tested as per 7.2.1.6 ☑ Complies ☐ Reject ☐ Retest Complies				
	Ensure that all bolts or nuts on any flanged connection or blank flange are in place and properly tightened ☑ Complies ☐ Reject ☐ Retest Complies				
Defects	REPLACE 3 COMPARTMENT LIDS - 2 HOSES RECERTIFIED AT GREGGS REPLACE 9 4 INCH VIC CLAMPS - REPLACE 2 1/4 PUSH CONNECT FITTINGS 1ST COMPARTMENT				
Tank Disposition					
Current Disposition	PASSED				
Inspector: NATHANIEL JONES	Signature Date: TUESDAY MAY 28TH 2019				

Test and Inspection Report in Accordance with CSA B620

Dandy Oil Products Ltd.

15 Challenger Crescent Sherwood Park, AB T8H 2J6

2 780-452-1104

Facility Registration # 25.0960

Leakage Test "K"						
Inspection Date	TUESDAY MAY 28TH 2019					
Inspection Date Expiry	SUNDAY MAY 31ST 2020					
PRV set to Discharge P	1.5 PSI					
Test Medium	AIR/ WATER					
Number of Compartments	3					
Compartment 1	Start (psi) 3.4 PSI	End (psi)	Hold Time (min)	Capacity		
Compartment 2	Start (psi)	3.4 PSI End (psi)	Hold Time (min)	14000 LITRES Capacity		
Compartment 3	3.4 PSI Start (psi)	3.4 PSI End (psi)	10 Hold Time (min)	5000 LITRES Capacity		
Compartment 4	3.4 PSI Start (psi) N/A	3.4 PSI End (psi) N/A	Hold Time (min)	14000 LITRES Capacity		
Compartment 5	Start (psi) N/A	End (psi)	N/A Hold Time (min) N/A	N/A Capacity N/A		
	Manways and closures inspected for leaks or deformation ☑ Pass ☐ Fail ☐ Retest Complies Flanged connections checked for leakage ☑ Pass ☐ Fail ☐ Retest Complies					
	Inspect the entire area of the head, shell and welds for leaks or deformation including voids and adjacent compartments ☑ Pass ☐ Fail ☐ Retest Complies					
	Test pressure maintained for minimum of 5 minutes ☑ Pass ☐ Fail ☐ Retest Complies					
	☑ Pass ☐ Fail ☐ I	Retest Complies	tes			
	☑ Pass ☐ Fail ☐ I	Retest Complies Defore the tank is marked	res			
Defects	☐ Pass ☐ Fail ☐ I All leaks are repaired I ☐ Pass ☐ Fail ☐ R REPLACE 3 COMPA	Retest Complies Defore the tank is marked etest Complies RTMENT LIDS - 2	HOSES RECERTIFIED AT CE 2 1/4 PUSH CONNEC	GREGGS T FITTINGS 1ST		
Defects Tank Disposition	☐ Pass ☐ Fail ☐ I All leaks are repaired I ☐ Pass ☐ Fail ☐ R REPLACE 3 COMPA REPLACE 9 4 INCH	Retest Complies Defore the tank is marked etest Complies RTMENT LIDS - 2	HOSES RECERTIFIED AT	GREGGS T FITTINGS 1ST		
	☐ Pass ☐ Fail ☐ I All leaks are repaired I ☐ Pass ☐ Fail ☐ R REPLACE 3 COMPA REPLACE 9 4 INCH	Retest Complies Defore the tank is marked etest Complies RTMENT LIDS - 2	HOSES RECERTIFIED AT	GREGGS T FITTINGS 1ST		